



**NOTICE TO INVITATION FOR BID (RFB)
BID No. LIFT STATION PUMPS LS-16-03-1
SUBMERSIBLE PUMPS (2)**

THE LAGUNA MADRE WATER DISTRICT IS ACCEPTING SEALED BIDS FROM QUALIFIED FIRMS TO PROCURE (2) SUBMERSIBLE PUMPS

SEALED BID WILL BE MARKED "LIFT STATION PUMPS BID # LS-16-03-1" AND DELIVERED TO: LAGUNA MADRE WATER DISTRICT, GENERAL MANAGER, 105 PORT ROAD, PORT ISABEL, TEXAS 78578.

BIDS, HOWEVER DELIVERED, MUST BE RECEIVED NO LATER THAN 2:00PM ON APRIL 4, 2016 AT WHICH TIME THEY WILL BE PUBLICLY OPENED. THE DISTRICT WILL NOT ACCEPT PROPOSALS AFTER THE DEADLINE.

THE LAGUNA MADRE WATER DISTRICT RESERVES THE RIGHT TO REJECT ANY OR ALL PROPOSALS, TO WAIVE ANY INFORMALITIES, AND TO HOLD PROPOSALS FOR A PERIOD OF 60 DAYS SUBSEQUENT TO PUBLIC OPENING.

BID PACKAGES MAY BE OBTAINED BY CONTACTING THE DISTRICT A/P PROCUREMENT AGENT FERNANDO GARCIA AT 956-943-2626 EXT. 235. SPECIFICATIONS AVAILABLE AT THE WEBSITE WWW.LMWD.ORG/BIDS

"AN EQUAL OPPORTUNITY EMPLOYER"

Laguna Madre Water District

105 Port Road, Port Isabel TX 78578

Bid Specifications

The following are the minimum requirements for (2) submersible pumps. All standard items appearing in the manufactures published specifications and a description of the manufacturer’s warranty information shall submitted with the bid proposal

All spaces must be filled in.

An approved equal may be substituted

Item No.		2	QUANTITY	Cost \$
1	A	2	25 HP 208/230/460/60/3 voltage/Hz/Phase 1750 RPM, 72.8/66.6 Amps High Chrome Impeller & Wear Plate 6" Discharge 60' power cord	
	B		Retrofit existing 6" EBARA base elbow	
	C		Temperature & seal failure relays into control panel	
	D		Delivery & Installation	

Warranty Period: _____

Total Cost \$ _____

Estimated delivery Date: _____

Estimated Installation Date: _____

Warranty information must be submitted with Bid, it will be a factor in evaluation and award of Bid.

Number of days required to deliver/install the pumps after receiving the order must stated on Bid.

Number of days and/or weeks stated on Bid proposal for complete delivery/installation will be a factor in the evaluation and award of bid.

When delay can be foreseen, successful bidder shall give prior notice to the District. Bidder must keep the District advised at all times of status of order. Default in promised delivery/installation (without acceptable reasons) or failure to meet specifications, authorizes the District to Purchase such sub-pump elsewhere and charge increase cost and handling to defaulting bidder.

Acceptable reasons for delayed delivery/installation are as follow: Acts of God (floods, tornadoes, hurricanes, etc.), Acts of Government (fire, strikes and war), Actions beyond the control of the successful bidder.

Laguna Madre Water District

105 Port Road, Port Isabel TX 78578

Lift Station # 21

Bid Specifications

Note: This proposal will be considered complete once the District test the pump and make sure it operates properly and does not leak

Addendum No. 1 _____

Received by: _____

Addendum No. 2 _____

Received by: _____

Company Name: _____

Address: _____

Phone & Fax #: _____

Signature: _____

Date: _____

LIFT STATION # 21 SUB PUMP SPECS

25 HORSE POWER

208/230/460/60/3 VOLTAGE/HZ/PHASE

1750 RPM, 72.8/66.6 AMPS

**HIGH CHROME IMPELLAR & WEAR
PLATE.**

6 INCH DISCHARGE

60 FOOT POWER CORD

**RETROFIT EXISTING 6" EBARA BASE
ELBOW.**

**DELIVERY & INTALLATION OF
PUMPS & TEMPERATURE & SEAL
FAILURE RELAYS INTO CONTROL
PANEL.**